## SSO Notification List

## **June 2009**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	6/3/2009	2600 N. Longwood Street	21216	Grease	Gwynns Falls	2:40	3:41 PM - 6:21 PM	Sewer Water and Grease	Evidence of Overflow	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	59356
2	6/4/2009	2616 Talbot Road	21216	Rags and Roots	Gwynns Falls	1:20	10:00 AM - 11:20 AM	Heavy Gray Water	Evidence of Overflow	Relieved H/C Choke with Pressure Truck	Turned over to be CCTV'ed	97365
3	6/4/2009	1929 E. 32nd Street	21218	Trash & Roots	Herring Run	2:45	9:15 AM - 12:00 PM	Gray Colored Water	165	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	97353
4	6/5/2009	4109 The Alameda	21218	Rags, Trash, Roots, Grease	Herring Run	2:45	12:30 PM - 3:15 PM	Gray Colored Water	825	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	97412
5	6/5/2009	1211 W. Northern Pkwy	21209	Rags	Herring Run	Undetermined	Unknown	Sewer Water and Paper Debris	Evidence of Overflow	Relieved House Connection Choke	Turned over to Construction to Repair H/C	97411
6	6/5/2009	2111 W. Northern Pkwy	21217	Rags & Trash	Jones Falls	0:30	12:02 PM- 12:32 PM	Gray Water and Paper	10	Relieved H/C with electric Cutting Head	Pumped Down the H/C	97408
7	6/6/2009	6800 Park Heights Ave	21215	Rags, Trash and Grease	Jones Falls	0:40	12:50 PM - 1:30 PM	Gray Colored Water	400	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	97446
8	6/7/2009	3600 Labyrinth Rd	21215	Rags and Grease	Gwynns Falls	1:00	9:34 Pm - 10:34 PM	Sanitary Water & Grease	300	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	97486
9	06/10/209	312 N. Martin Luther King Blvd	21201	Pipe Break	Inner Harbor	1:30	9:30 AM - 11:00 AM	Gray Water and Paper Debris	Evidence of Overflow	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	97586
10	6/12/2009	6800 Park Heights Ave	21215	Grease	Jones Falls	0:50	8:45 PM - 9:35 PM	Sewer Water	500	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	59688
11	6/12/2009	2500 W. Franklin Street	21223	Grease	Patapsco	6:32	4:21 PM - 10:53 PM	Sewer Water and Grease	1,960	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	59679
12	6/17/2009	3509 E. North Ave	21213	Rags & Trash	Herring Run	2:00	8:30 Am - 10:30 AM	Rags and Gray Water	360	Relieved M/L Choke with Pressure Truck	CCTV Inspected	97904
13	6/21/2009	4705 Melbourne Rd	21229	Rags, Roots and Grease	Gwynns Falls	2:00	1:34 PM - 3:34 PM	Heavy Gray Water	600	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	98072
14	6/22/2009	4159 Patterson Ave	21215	Rags and Grease	Gwynns Falls	3:33	4:28 PM - 8:01 Pm	Sewer Water, Grease, Rags and Paper	2,130	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	59973
15	6/24/2009	2300 Lipps Lane	21223	Rags and Debris	Gwynns Falls	2:00	11:00 AM - 1:00 PM	Heavy Gray Water	120	Relieved Connection with electric Cutting Head	Turned over to be CCTV'ed	98210
16	6/25/2009	5001 W. Northern Parkway	21207	Rags, Trash and Roots	Gwynns Falls	6:58	6/25/09 5:22 PM to 12:20 AM 6/26/09	Sewer Water, Grease, Rags and Paper	2,926	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	98263
17	6/26/2009	1499 Anglesea Street	21224	Grease	Inner Harbor	3:39	1:53 pm - 5:32 pm	Sewer Water and Grease	1,395	Relieved Choke with Pressure Jet	Turned over to be CCTV'ed	60094
18	6/26/2009	6500 Eastern Avenue	21224	Debris	Colgate Creek to Patapsco River	0:25	9:30 PM - 9:55 PM	Sewer Water	250	Relieved Choke with Pressure Jet	Turned over to be CCTV'ed	60105
19	6/29/2009	2435 Foster Ave	21224	Debris	Patapsco	3:27	3:18 PM - 6:45 PM	Sewer Water and Paper Debris	Evidence of Overflow	Relieved M/L Choke with Cleaning Machine	Turned over to be CCTV'ed	60177
20	6/29/2009	5824 Greenspring Ave	21209	Debris	Gwynns Falls	5:37	12:54 PM - 6:27 PM	Paper Debris	Evidence of Overflow	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	60172
21	6/29/2009	5300 Falls Road	21210	Rags and Roots	Jones Falls	2:00	9:00 AM - 11:00 AM	Heavy Gray Water	360	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	98338
								TOTAL	12,301			